

VAM-**-05-L-GR-OP2**
Fibre optics




1258



- Fibre optics with special steel, 1.4301 protection sheath and stainless steel reinforcement for light barrier measurement arrangements.

Technical Data	VAM-****-05-L-GR-OP2	
Gas Ex protection designation	II 1G Ex op is IIB T4 Ga	
Dust Ex protection designation	II 1D Ex op is IIIB T135°C Da	
For use in Ex Zones	1, 2, 21 and 22	
Permitted sensors	Only for operating with ATEX/IECEX certificated sensors from Matrix Elektronik AG	
Maximum optical input power	<=35mW	
Maximum optical input intensity	<=5mW/mm ²	
Total length	****=Length in mm, 500, 1000, 2000 (Overall length)	
Active fibre optic diameter	4.7mm	
Active cross-sectional area	17.34mm ²	
Single fiber diameter	50um	
Average transmission	50-70% at 870nm	
Optical acceptance angle	approx. 65° at 870nm	
Minimum bending radius	50mm (Single bend)	
Materials	protection sheath:	Special steel, 1.4301
	probe tip:	Special steel, 1.4305
	adaption probe tip:	Special steel, 1.4305
Enclosure rating	IP68	
Ambient working temperature range, T _{amb}	-20°C up to +120°C	
Accessories	Included	Optional
	• 2x Shrink-down plastic tubing	

Dimensions



EX related markings

CE 1258
 Gas: Ⓜ II 1G Ex op is IIB T4 Ga
 ATEX:
 IECEX:
 Tamb: -20°C up to +120°C
 (X designation of the certification number: Fibre optics must only be applied with sensors with certificated limited optical power).

Manufacturing date: Digits 5 to 8 of the serial number(Year / CW)
 Dust: Ⓜ II 1D Ex op is IIIB T135°C Da
 BVS 10 ATEX E 130 X
 IECEX BVS 14.0108X
 Manufacturer with address

Operating Manual / EU-declaration of conformity

Ex installation prescriptions

It is necessary to take into consideration the valid international and national rules and regulations (IEC 60079-14). The optical fibre must only be operated with ATEX/IECEX homologated sensors from Matrix Elektronik AG. The maximum rated optical input power must not be exceeded. The local equipotential bonding have to be done by grounding the fixed sensor. Other than original manufacturer, additional optical lenses are not allowed in hazardous locations. The fibre optics have to be installed in a manner that avoids tensile stress and frictional heat. If fibre optics and associated sensors are not mounted in the same hazardous location, the change over of the different areas must be realized in accordance with the valid regulations. The product VAM-****-05-L-GR-OP2 is applicable in Ex zones 1, 2, 21 and 22.

Function

The fibre optics series VAM-****-05-L-GR-OP2 are designed for the construction of light barrier measurement method arrangements in hazardous locations and for high ambient temperatures. The fibre optics must only be operated with certificated Matrix sensors, with limited optical radiation power and with an optical wave length from 500nm to 900nm. The fibre optics must not be buckled or laid with a small radius. Buckled or bad laid fibre optics results to a strong decrease of performance. Avoid performance decreasing and failures caused by wear, by a functional mounting of the fibre optics.

General safety

When installing and operating the product, it is necessary to take into consideration all relevant international and other national regulations, especially those regarding explosion protection.

Maintenance

No special maintenance is required. Protect the product and any optical ports (if applicable) from pollution. Clean with **non-aggressive** solvents only. Strong solvents may damage certain fibre optics. The equipment must only be repaired or serviced by the manufacturer.

General notes and disposal

We reserve the right to modify our equipment. Our equipment is designed such way, that it has the least possible adverse effect on the environment. It neither emit or contain any damaging or siliconized substances and use a minimum of energy and resources. No longer usable or irreparable units must be disposed of in accordance with local waste disposal regulations.

EU-Declaration of Conformity

The product meets the requirements of the following standards and directives:
 EN IEC 60079-0:2018, IEC 60079-28:2015, IEC 60079-31:2013, ATEX directive 2014/34/EU, Machine directive 2006/42/EC, RoHS directive 2011/65/EU
 ATEX/IECEX-Designation:
 Gas: II 1G Ex op is IIB T4 Ga
 Dust: II 1D Ex op is IIIB T135°C Da
 ATEX EU-type examination certificate No.: BVS 10 ATEX E 130 X
 IECEX CoC No.: IECEX BVS 14.0108X
 Ex CB IECEX: DEKRA Testing and Certification GmbH, Carl-Beyling-Haus, Dinen-dahlstrasse 9, D-44809 Bochum.
 ATEX certification of quality management system, type production of Ex devices, in accordance to the directive 2014/34/EU:
 Certification No.: SEV 21 ATEX 4580, QAR No.: CH/SEV/QAR21.0009/00, CB: Eurofins Electric & Electronic Product Testing AG, Luppmenstrasse 3, CH-8320 Fehraltorf. CE 1258 Ident. Number: 1258
 Pablo Ledergerber, Matrix Elektronik AG, is authorized to generation of documentation. The conformity of the devices with all used standards and directives and the EC-type examination certificate and the observation of the Quality Management System ISO 9001:2015, declares:

Ehrendingen, 23.2.2022

Pablo Ledergerber, Matrix Elektronik AG

VAM-xxxx-05-L-GR-OP2_e1/2022-02-23/MPP

Matrix Elektronik AG (Manufacturer)
 Kirchweg 24, CH-5420 Ehrendingen
 Tel.: +41 56 20400-20, Fax -29
 info@matrix-elektronik.com
Tippkemper-Matrix GmbH
 Meegerer Str. 43, D-51491 Overath
 Tel.: +49 2206 9566-0, Fax -19
 info@tippkemper-matrix.de